

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:14 pm

PWS ID: UTAH29084 **Name:** AMERICAN LEGION POST 129
Legal Contact: AMERICAN LEGION **Rating:** Not Approved
 LYNN COOK 'WOODY' SUMMERS **Rating Date:** 02/03/2010
Address: 3722 E 4100 N **Activity Status:** Active
 LIBERTY, UT 84310
Phone Number: 801-745-3856
City Served (Area):
County: WEBER COUNTY
System Type: Non-community **Last Inv Update:** 11/20/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 11/17/2009 **Total Dsgn Cap:**
Population: 100 **Surveyor:** LAURA SHOEMAKER **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	SUMMERS, LYNN COOK 'WOODY'		801-791-1772	801-430-5041	WOODYSUMMERS@LIVE.C

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	1
			1 Total Svc Connections

Storage

Total Storage: 40 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	40 GAL	Steel		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	AMERICAN LEGION WELL 1	Active	WL	6	20 GPM	40 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.